

Saline County, Kansas

Facility Name	Date
Contact Name _____	Title
Facility Address _____	Phone

Retail Fireworks Stand - Final Inspection Checklist

ITEM #	DESCRIPTION	✓ ONE		COMMENTS
		YES	NO	
1	Posted sign reading "FIREWORKS FOR SALE - NO SMOKING ALLOWED" in letters at least 2" high			
2	Fireworks not sold or kept near paint, varnishes, turpentine, gasoline or other flammable substances unless in a completely separate and distinct section of the store			
3	Two U.L. listed 10# 4A:80B:C fire extinguishers provided and kept in close proximity. (Stands <800 sq. ft. are only required to have one 10# ABC fire extinguisher.)			
4	Fire extinguishers must be located so that they are never farther than 35' from any point in the structure.			
5	Remind Licensee that permitted sale dates are from June 27 through July 5 between the hours of 8:00 a.m. and 12:00 a.m. (midnight).			
6	If displayed behind glass in sunny conditions, the merchandise must be in original packaging			
7	Signs reading "NO FIREWORKS DISCHARGE WITHIN 300 FEET" in letters at least 4" high on a contrasting background posted on all sides of stand			
8	Stand is at least 50' from any aboveground bulk storage or bulk dispensing area for flammable or combustible liquid, flammable gas or flammable liquefied gas.			
9	Stand is at least 50' from any other tent, stand, building or fireworks storage area			
10	Stand is at least 50' from any right-of-way.			
11	Stand is at least 50' from any fireworks storage area.			
12	Stand is at least 30' from any combustibles (dry grass, dry brush, combustible debris).			
13	Stand is at least 20' from any portable generators and generator fuel.			
14	Stand is at least 10' from any vehicle parking area			

Retail Fireworks Stand - Final Inspection Checklist - Page 2

ITEM #	DESCRIPTION	✓ ONE		COMMENTS
		YES	NO	
15	Exterior lights are pointed away from adjacent properties and rights of way.			
16	No less than three (3) exits shall be provided. Exits cannot pass through storage rooms. Exit points in <u>tents</u> cannot be farther than 75' from each other; exit points in <u>stands</u> cannot be farther than 35 feet from each other.			
17	Exit signs are required per NFPA 101. Signs must either be self-luminous, internally or externally illuminated.			
18	Aisles, doors and exit discharge must be at least 4' wide and remain unobstructed at all times. All aisles must terminate at either an exit or another aisle; no dead end aisles are allowed.			
19	Internal walls or displays can be no more than 6' high.			
20	No fireworks shall be displayed for sale or stored within 5' of any entrance or within 2' of any exit.			
21	No display areas shall be longer than 32' without a 4' flame break.			

If "No" is checked on any item on this Inspection Sheet a license to operate shall not be issued until the deficiency is corrected and another inspection is conducted and passed.

This facility (Initial One): PASSED _____ FAILED _____

Inspector's Name (Please Print): _____

Title / Agency:

Signature:
